

RFP2022-02 Questions

- 5.09.2022 1 Which set of plans from the website do we use?
- 5.09.2022 2 Please provide a window schedule.
- 5.09.2022 3 Need specs for the mini blinds.
- 5.09.2022 4 Provide specs for the new exit light fixture
- 5.09.2022 5 Legend found in sheet TE1.01 identifies a "Wall Washer Fixture" but these are not identified in the Electrical Lighting Plan. Can you clarify if these are needed? If so, please provide specs and location.
- 5.09.2022 6 Page 10 of 17 of the RFP has "Furnish and install 8 new 2 x 4 building standard light fixtures but plans only show 18 to be relocated. Can you clarify if these are part of the scope? If so, please provide specs and location.
- 5.09.2022 7 During the mandatory site visit it was mentioned one door was in stock, please confirm and identify which handed door was mentioned.
- 5.09.2022 8 On signage only 3 exit signs were mentioned. Is this the extent of signage, as nothing else was scheduled?
- 5.09.2022 9 Detail 08/TD1.00 shows installation heights for "Typical Door Signs". Please confirm if these are part of the scope. If so, please provide schedule and specs.

Answers

The set that is dated April 18, 2022: HCAD-LV 1 ARB

The plans call for no new windows, so there is no window schedule.

Blinds are by the owner

Please match the existing exit signs. If that is not possible due to age, we can provide a new specification.

There are no "Wall Washer Fixture" shown on the Electric Lighting Plan, so none are required.

The 8 new 2 x 4 building standard light fixtures are not part of the scope.

Both swings of doors are used on the project so, it can be determined after the contractor is selected. Your bid should include one door available from building stock.

These are the only signs that are part of the scope, with the single exception of any temporary regulatory signs that are part of the construction process, if required.

Signs are not part of the scope other than signs mentioned in Answer 7 above.